

Certificate of Conformity

issued by Curtis-Straus LLC, a wholly owned subsidiary of BV CPS

Company: Sixnet, LLC
Product Tested: EL212F-AC-V1
Testing Date: January 11, 13, and February 2 to March 29, 2011
Report No.: EL0070-2

A sample of the product as configured in the accompanying test report has been found to comply with the following standards:

EMC Emissions:

- EN 55022:2006/A1:2007 Class B ITE emissions requirements (EU)
- ICES-003 Issue 4 Class B Digital Apparatus emissions requirements (Canada)

EMC Immunity:

- IEEE 1613:2009 Testing Requirements for Communications Networking Devices Installed in Electric Power Substations – *for the following tests only:*
 - Section 5.2: Dielectric Power Frequency Test
 - Section 5.3 Impulse Voltage Test
 - Section 6: Oscillatory Test
 - Section 6: EFT Test
 - Section 8: Electrostatic Discharge

EMC Immunity:

- IEC 61850-3:2002 Communication networks and systems in substations – *for the following tests only:*
 - Radiated and Conducted Emissions
 - Radiated RF Immunity
 - EFT Immunity
 - Surge Immunity
 - Conducted RF Immunity
 - Magnetic Field Immunity
 - Low Frequency Conducted Immunity
 - DC Voltage Ripple
 - DC Dips and Interruptions
 - AC Dips and Interruptions
 - Damped Oscillatory
 - DC Voltage Reverse Polarity
 - DC Voltage Below Lower Voltage Limit
 - DC Voltage Earthing
 - DC Voltage Range/Tolerance

Attested to by the hands and seals:

For Curtis-Straus LLC

For the Manufacturer or Importer

 06/20/11
 Test Engineer Date

Date

 6/20/11
 EMC Manager Date